

# REQUEST FOR INSPECTION

CALL DATE: 3/1/2023 TIME \_\_\_\_\_: \_\_\_\_\_ AM / PM

PROPERTY ADDRESS: 201 Kinkaid School Drive PERMIT NUMBER: \_\_\_\_\_

### INSPECTOR

Bob Baldwin 
  Jason Bienek 
  Cary Moran 
  Jose Gomez 
  City Engineer Coleman / HDREnc 14

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Linbeck

CONTACT PHONE/EMAIL: Chris Manes

INSPECTOR COMMENTS: to look @ connections

per our discuss - in the field.

- make clean up & field improvements

per - Annette.

*AP*

- Need RFFF placed before tomorrow - pictures or Jose to check.

- Need final connection to Junction box upstream of Det. pond.

- Require plan resubmission. Plans dated 11-8-22 have city seal? but no engineer approval.

PASS FAIL

DATE: 3-7-23

TIME: 12:30

INSPECTOR: Coleman

Re-Inspection Fee Required