

Central Plant

REQUEST FOR INSPECTION

CALL DATE: 6/5/2023 TIME: _____ : _____ AM / PM

PROPERTY ADDRESS: 201 Linkard School LDR PERMIT NUMBER: 19289

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer Cole HDR Eng'g

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel - Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping - Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	<u>Drainage Partial</u>	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Antonio Rojas w/ Linbeck

CONTACT PHONE/EMAIL: (832) 542-4060 (p)

INSPECTOR COMMENTS: partial cover Central Plant storm pipe.

PASS **FAIL**

DATE: 6-5-23

TIME: 11:00

INSPECTOR: Cole HDR

Re-Inspection Fee Required

OK to cover pipe along east side to corner of baseball field.
