

REQUEST FOR INSPECTION

CALL DATE: 12/5/23 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 205 Merrick Way PERMIT NUMBER: #18412

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer Cole w/ HDR

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	<u>Drainage Final</u>	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Dennis Williams
 CONTACT PHONE/EMAIL: # 713.465.7231
 INSPECTOR COMMENTS: Dennis Williams + CO. INC
Gate Code: 0804

PASS FAIL

DATE: 12/5/23
 TIME: 11:15
 INSPECTOR: Cole

Re-Inspection Fee Required

- Cleanout south of inlet 31 covered, not accessible as shown on plan.
- Inlet 34 in landscaping area by gate curbed cleanout are covered or have been removed, but are shown on drainage plan. Revise plan or place/uncover inlet, cleanout, pipe.
- Final inspection site should be complete, ready for move-in, site is incomplete.
- Remove all filter fabric.