

REQUEST FOR ELECTRICAL INSPECTION

DATE: 1-7-21 TIME 11:30: AM / PM

JOB ADDRESS: 11106 WICKDALE

PERMIT NUMBER: 17481

INSPECTION DATE:

Codes Used: NFPA 70 - NEC 2017

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- | | |
|-------------------------------------------------------|----------------------------------------------------------|
| 1. Temp Sump Pump Connection <input type="checkbox"/> | 1. Electrical Pool Cover <input type="checkbox"/> |
| 2. T-pole <input type="checkbox"/> | <u>2. Electrical Pool Final</u> <input type="checkbox"/> |
| 3. Ditch Cover <input type="checkbox"/> | 1. Generator Ditch Cover <input type="checkbox"/> |
| 4. Slab Cover <input type="checkbox"/> | 2. Generator Electrical Final <input type="checkbox"/> |
| 5. Wall / Ceiling Cover <input type="checkbox"/> | 1. Partial / See Comments <input type="checkbox"/> |
| 6. TCI <input type="checkbox"/> | |
| 7. Meter Loop And Service <input type="checkbox"/> | |
| 8. Reconnect <input type="checkbox"/> | |
| 9. Electrical Final <input type="checkbox"/> | |
| 10. Landscape Lighting Cover <input type="checkbox"/> | |
| 11. Landscape Lighting Final <input type="checkbox"/> | |

PASS	<u>FAIL</u>
DATE:	<u>1-7-21</u>
TIME:	
INSPECTOR:	<u>JB</u>

CONTRACTOR/CALLER NAME: Serv Tech Electric

CONTACT TEL/PGR/MOBILE: Calvin 281-794-2457

INSPECTOR COMMENTS:

Need to label panel
(1) light in pool Not working

Reinspection fee required