





# REQUEST FOR ELECTRICAL INSPECTION

DATE: 1-25-21 TIME 9:11: AM / PM

JOB ADDRESS: 2 Willowick Creek

PERMIT NUMBER: 17587

INSPECTION DATE:

Codes Used: NFPA 70 - NEC 2017

ELECTRICAL INSPECTORS: 1) Jason Bienek 2) Bob Baldwin

- |                              |                          |                               |                          |
|------------------------------|--------------------------|-------------------------------|--------------------------|
| 1. Temp Sump Pump Connection | <input type="checkbox"/> | 1. Electrical Pool Cover      | <input type="checkbox"/> |
| 2. T-pole                    | <input type="checkbox"/> | 2. Electrical Pool Final      | <input type="checkbox"/> |
| 3. Ditch Cover               | <input type="checkbox"/> | 1. Generator Ditch Cover      | <input type="checkbox"/> |
| 4. Slab Cover                | <input type="checkbox"/> | 2. Generator Electrical Final | <input type="checkbox"/> |
| 5. Wall / Ceiling Cover      | <input type="checkbox"/> | 1. Partial / See Comments     | <input type="checkbox"/> |
| 6. TCI                       | <input type="checkbox"/> |                               |                          |
| 7. Meter Loop And Service    | <input type="checkbox"/> |                               |                          |
| 8. Reconnect                 | <input type="checkbox"/> |                               |                          |
| <u>9. Electrical Final</u>   | <input type="checkbox"/> |                               |                          |
| 10. Landscape Lighting Cover | <input type="checkbox"/> |                               |                          |
| 11. Landscape Lighting Final | <input type="checkbox"/> |                               |                          |

|            |                |
|------------|----------------|
| PASS       | <u>FAIL</u>    |
| DATE:      | <u>1-25-21</u> |
| TIME:      | <u>9:11</u>    |
| INSPECTOR: | <u>JB</u>      |

CONTRACTOR/CALLER NAME: Bradford Brothers

CONTACT TEL/PGR/MOBILE: FRANK 281-615-6027

INSPECTOR COMMENTS:

No Access - Called Frank no answer  
mailbox full

Need correct breakers  
Need to lower panel

Reinspection fee required