

# REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 1-27-21 TIME: 9 AM / PM

JOB ADDRESS: 22 S. Checka Lane

PERMIT NUMBER: 17516

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site Good    Poor
- Verbal Warning    Site Cleaned at Insp.    City Citation Issued    City Notified

INSPECTOR: Bob Baldwin

INSPECTION DATE: 1-27-21

## PLUMBING

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

## MECHANICAL

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover   
(need MVFD approval)
- 6. Fire Sprinkler Final

<b>PASS</b>	<b>FAIL</b>
DATE: <u>1-27-21</u>	
TIME: <u>11:40</u>	
INSPECTOR: <u>Bob B 3330</u>	

CONTRACTOR/CALLER NAME: Palmer Plumbing

CONTACT TEL/PGR/MOBILE: Sergio 832 88 3686

INSPECTOR COMMENTS:

No shower pan approval, separate inspection will wall board # installed, no green board to back on water test.

Reinspection fee required