

REQUEST FOR PLUMBING / MECHANICAL INSPECTION

DATE: 1-5-21 TIME: _____ : _____ AM / PM

JOB ADDRESS: 3 Derham Park Sf.

PERMIT NUMBER: 16903

- Pass Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass Fail Trash Anywhere on Property
- Pass Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass Fail Dumpster full to the Lip & Needs to be Serviced
- Pass Fail Port-O-Can Door Facing Away From Street
- Pass Fail Port-O-Can Screened and/or Needs Maintenance
- Pass Fail Tree Protective Fencing Down
- Pass Fail Filter Fabric Fencing Down
- Pass Fail High Grass and/or Tall Weeds
- Pass Fail Overall Condition of Construction Site Good _____ Poor
- _____ Verbal Warning _____ Site Cleaned at Insp. _____ City Citation Issued _____ City Notified

INSPECTOR: Bob Baldwin

INSPECTION DATE: 1-5-21

PLUMBING MECHANICAL

- 1. Water line
- 2. Rough In
- 3. Top Out
- 4. Shower Pan
- 5. Sewer Line
- 6. WC Flange
- 7. GTO
- 8. Plumbing Final
- 9. Pool Drainage
- 10. Site Drainage
- 11. Irrigation Final
- 12. Other

- 1. Vent Hood
- 2. Rough/cover
- 3. Mech Final
- 4. Water Heater Final
- 5. Fire Sprinkler cover (need MVFD approval)
- 6. Fire Sprinkler Final

PASS	<u>FAIL</u>
DATE:	<u>1-25-21</u>
TIME:	<u>11:15</u>
INSPECTOR:	<u>BBB</u>

CONTRACTOR/CALLER NAME: Southern Plumbing

CONTACT TEL/PGR/MOBILE: David 832 231 7521

INSPECTOR COMMENTS:

Need to caulk toilets to floor.
Install vacuum breakers on all hose bibs
on property.

Reinspection fee required