

# REQUEST FOR STRUCTURAL INSPECTION

CALL DATE: 1-25-21 TIME: \_\_\_\_\_ : \_\_\_\_\_ AM / PM

PROPERTY ADDRESS: 11302 James Lane

PERMIT NUMBER: 17402

- Pass  Fail Street Clean In Front of Property- (Nothing in Gutter)
- Pass  Fail Dirt, Mud, Construction Tracks in Front of Property
- Pass  Fail Trash Anywhere on Property
- Pass  Fail O-Tolerance for Lunch Trash This May Result in Project to be Temporarily Shut Down!
- Pass  Fail Dumpster full to the Lip & Needs to be Serviced
- Pass  Fail Port-O-Can Door Facing Away From Street
- Pass  Fail Port-O-Can Screened and/or Needs Maintenance
- Pass  Fail Tree Protective Fencing Down
- Pass  Fail Filter Fabric Fencing Down
- Pass  Fail High Grass and/or Tall Weeds
- Pass  Fail Overall Condition of Construction Site \_\_\_ Good \_\_\_ Poor  
\_\_\_ Verbal Warning \_\_\_ Site Cleaned at Insp. \_\_\_ City Citation Issued \_\_\_ City Notified

DATE: \_\_\_\_\_ TIME: \_\_\_\_\_ AM/PM

INSPECTOR (1) Jason Bienek 2) Bob Baldwin \_\_\_\_\_

## INSPECTION TYPE

- |                            |                          |                               |                          |
|----------------------------|--------------------------|-------------------------------|--------------------------|
| 1. PRE CONSTRUCTION SITE   | <input type="checkbox"/> | 1. POOL STAKE OUT/POOL SET-UP | <input type="checkbox"/> |
| 2. PIERS                   | <input type="checkbox"/> | 2. POOL STEEL                 | <input type="checkbox"/> |
| 3. FOUNDATION STEEL        | <input type="checkbox"/> | 3. POOL DECK/PATIO STEEL      | <input type="checkbox"/> |
| 4. RIDGE HEIGHT            | <input type="checkbox"/> | 4. POOL BARRIER               | <input type="checkbox"/> |
| 5. HURRICANE TIES          | <input type="checkbox"/> | 4. POOL FINAL                 | <input type="checkbox"/> |
| 6. STUCCO LATHE/BRICK TIES | <input type="checkbox"/> | 1. FENCE POST HOLE            | <input type="checkbox"/> |
| 7. FRAMING / FRAMING COVER | <input type="checkbox"/> | 2. FENCE FINAL                | <input type="checkbox"/> |
| 8. BUILDING FINAL          | <input type="checkbox"/> | 1. DRIVEWAY/FLATWORK FORMS    | <input type="checkbox"/> |
| 9. TREE FINAL              | <input type="checkbox"/> | 2. DRIVEWAY FINAL             | <input type="checkbox"/> |
| 10. ROOF Final/ DEMO FINAL | <input type="checkbox"/> | 3. OTHER                      | <input type="checkbox"/> |
| 11. Generator Steel        | <input type="checkbox"/> | 4. TRENCH                     | <input type="checkbox"/> |
| <u>12. Generator Final</u> | <input type="checkbox"/> | 5. TEMP FENCING               | <input type="checkbox"/> |

CONTRACTOR/CALLER NAME: Hirsch Service

CONTACT TEL/PGR/MOBILE: Clayton

INSPECTOR COMMENTS: 979-224-6593

Need Electrical Final  
Transfer Switch to high  
Cannot Run wire and lead through gutter

PASS	<u>FAIL</u>
DATE:	<u>1-25-21</u>
TIME:	
INSPECTOR:	<u>TB</u>

Reinspection fee required