REQUEST FOR INSPECTION

CALL DATE: 8:3-21 TIME 12:00 AM/PM PROPERTY ADDRESS: 533 Piney Point PERMIT NUMBER: 18045		
INSPECTION INFORMATION INSPECTOR: Bob Bald vin Jason Bienek Cary Moran City Engineer		
Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final	Mechanical Change Out
Wall Board Exterior	Pool Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TO Reconnect	Plumbing Sewer Line
Poly Seal	Pool Electricar Underground	Plumbing Ground
Insulation	Pool Electrical Cover	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Final	Plumbing Gas (GTO- House)
Brick Tie	Electrical Final	Plumbing Cover
Stucco Lathe	Temporary Drainage	Plumbing Final
Building Final	Drainage Partial	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Drainage Final	Plumbing Pool Final
Driveway Final	Fire Sprinkler Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Final	Irrigation Final
Sidewalk/Flatwork/Paver Final	Other/Miscellaneous	PASS FAIL
CONTRACTOR NAME: 6215	5 lectair	DATE: 8-3-21
CONTACT PHONE/EMAIL: 6,115 832-722.4875		TIME: 1:40
INSPECTOR COMMENTS:		INSPECTOR: Jasan
Released to Trace 3 1:40 pm @		
Center point		
- Carragains		

☐ Re-Inspection Fee Required