

# REQUEST FOR INSPECTION

CALL DATE: 8-5-21 TIME 12:45 AM/PM (P)  
 PROPERTY ADDRESS: 20 Farnham Park  
 PERMIT NUMBER: 17641

## INSPECTION INFORMATION

DATE PERFORMED: \_\_\_\_\_ TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 INSPECTOR: 1) Bob Baldwin \_\_\_\_\_ 4) Jason Bienek \_\_\_\_\_  
 2) Cary Moran \_\_\_\_\_ 5) Other \_\_\_\_\_  
 3) City Engineer \_\_\_\_\_

|                                     |                                    |   |
|-------------------------------------|------------------------------------|---|
| Demolition (Main House)             | Sidewalk/Flatwork/Pavers Steel     | Electrical Ditch Cover                          |
| Demolition (Pool Only)              | Sidewalk/Flatwork/Paver Final      | Electrical TCI                                  |
| Temporary Tree Protection Fencing   | Generator Concrete Steel Pad       | Electrical Final                                |
| Pre-Construction Site               | <u>Generator Final - Operative</u> | Mechanical Vent Hood                            |
| Piers                               | Partial Trench Inspection          | Mechanical Grill Seal                           |
| Foundation Repair                   | Trench Inspection                  | Mechanical Box Seal                             |
| Foundation Steel – Survey Verified  | Irrigation Final                   | Mechanical Air Make Up                          |
| Hurricane Strapping – Exterior Wall | Fence Partial Post Hole            | Mechanical Final                                |
| Wall Board Exterior                 | Fence Post Hole                    | Mechanical Cover (Wine Room)                    |
| Ridge Height                        | Fence Final                        | Mechanical Final (Wine Room)                    |
| Stair Compliance                    | Temporary Drainage                 | Fire Sprinkler Cover                            |
| Framing Only                        | Drainage Partial                   | Fire Sprinkler Final                            |
| Frame Cover                         | Drainage Cover                     | Pool Stake Out & Pool Doc Box Set Up            |
| Poly Seal                           | Drainage Culvert                   | Deck Steel                                      |
| Insulation                          | Drainage Final                     | Deck Final                                      |
| Wall Board Interior                 | Plumbing Water Line                | Pool Final                                      |
| Brick Tie                           | Plumbing Sewer Line                | Pool Electrical Underground                     |
| Stucco Lathe                        | Plumbing Ground                    | Pool Electrical Cover                           |
| Building Final                      | Plumbing Shower Pan/Wall Board     | Pool Electrical Final                           |
| Tree Final                          | Plumbing Gas (GTO- House)          | Pool Plumbing Cover                             |
| Driveway / Partial                  | Plumbing Cover                     | Pool Plumbing Vacuum Breaker, P-Trap, Gas Final |
| Driveway / Steel                    | Plumbing Final                     | Plumbing Pool Final                             |
| Driveway Final                      | Electrical T-Pole                  | Water Heater Final                              |

CONTRACTOR NAME: Generator Supercenter  
 CONTACT PHONE/EMAIL: Justin 281-251-6100  
 INSPECTOR COMMENTS: \_\_\_\_\_

|                         |             |
|-------------------------|-------------|
| PASS                    | <u>FAIL</u> |
| DATE: <u>8-5-21</u>     |             |
| TIME: <u>12:45</u>      |             |
| INSPECTOR: <u>Jason</u> |             |

Need to screen generator  
generator must be ready to test  
Need flexible connection at generator

Re-Inspection Fee Required