

REQUEST FOR INSPECTION

CALL DATE: 6/15/2022 TIME : AM / PM
 PROPERTY ADDRESS: 215 Hedwig Rd. PERMIT NUMBER: # 19056

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer Ann Cooley

| | | |
|-------------------------------------|--------------------------------------|--------------------------------------|
| Demolition | Generator Concrete Steel Pad | Mechanical Cover |
| Temporary Tree Protection Fencing | Generator Final - Operative | Mechanical Vent Hood |
| Pre-Construction Site | Fence Post Hole | Mechanical Grill Seal |
| Piers | Fence Final | Mechanical Box Seal |
| Foundation Repair | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up |
| Foundation Steel – Survey Verified | Deck Steel / Pool Steel | Mechanical Final |
| Hurricane Strapping – Exterior Wall | Deck Final / Pool Final | Mechanical Change Out |
| Wall Board Exterior | Roof Final | Mechanical Cover (Wine Room) |
| Ridge Height - Verification | Synthetic Turf | Mechanical Final (Wine Room) |
| Stair Compliance | Electrical T-Pole | Sewer Disconnect |
| Framing Only | Electrical Cover | Plumbing Water Line |
| Frame Cover | Electrical Ditch Cover | Plumbing Sewer Line |
| Poly Seal | Electrical TCI | Plumbing Ground |
| Insulation | Electrical Reconnect | Plumbing Shower Pan/Wall Board |
| Wall Board Interior | Pool Electrical Underground | Plumb Gas: House / Pool / Generator |
| Brick Tie | Pool Electrical Cover | Plumbing Cover |
| Stucco Lathe | Pool Electrical Final | Plumbing Final |
| Building Final | Electrical Final | Pool Plumbing Cover |
| Tree Final | Temporary Drainage | Pool Plumbing Vacuum Breaker, P-Trap |
| Driveway / Steel | Drainage Partial | Plumbing Pool Final |
| Driveway Final | Drainage Cover | Water Heater Final |
| Sidewalk/Flatwork/Pavers Steel | <u>Drainage Final</u> | Irrigation Trench / Final |
| Sidewalk/Flatwork/Paver Final | Fire Sprinkler Cover / Final | Other/Miscellaneous |

CONTRACTOR NAME: 4 A Group
 CONTACT PHONE/EMAIL: (7) 5458179
 INSPECTOR COMMENTS: te. 7. Drainage final cover

PASS **FAIL**

DATE: 6/16/22
 TIME: 12:30
 INSPECTOR: Ann Cooley

Pass for temp. drainage

Re-Inspection Fee Required

REQUEST FOR INSPECTION

CALL DATE: 6/8 215 Hedwig TIME 6 : AM / PM

PROPERTY ADDRESS: 78# 18650 PERMIT NUMBER: 18650

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer Aaron Crowley
4 APR

| | | |
|-------------------------------------|--------------------------------------|--------------------------------------|
| Demolition | Generator Concrete Steel Pad | Mechanical Cover |
| Temporary Tree Protection Fencing | Generator Final - Operative | Mechanical Vent Hood |
| Pre-Construction Site | Fence Post Hole | Mechanical Grill Seal |
| Piers | Fence Final | Mechanical Box Seal |
| Foundation Repair | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up |
| Foundation Steel – Survey Verified | Deck Steel / Pool Steel | Mechanical Final |
| Hurricane Strapping – Exterior Wall | Deck Final / Pool Final | Mechanical Change Out |
| Wall Board Exterior | Roof Final | Mechanical Cover (Wine Room) |
| Ridge Height - Verification | Synthetic Turf | Mechanical Final (Wine Room) |
| Stair Compliance | Electrical T-Pole | Sewer Disconnect |
| Framing Only | Electrical Cover | Plumbing Water Line |
| Frame Cover | Electrical Ditch Cover | Plumbing Sewer Line |
| Poly Seal | Electrical TCI | Plumbing Ground |
| Insulation | Electrical Reconnect | Plumbing Shower Pan/Wall Board |
| Wall Board Interior | Pool Electrical Underground | Plumb Gas: House / Pool / Generator |
| Brick Tie | Pool Electrical Cover | Plumbing Cover |
| Stucco Lathe | Pool Electrical Final | Plumbing Final |
| Building Final | Electrical Final | Pool Plumbing Cover |
| Tree Final | Temporary Drainage | Pool Plumbing Vacuum Breaker, P-Trap |
| Driveway / Steel | <u>Drainage Partial</u> | Plumbing Pool Final |
| Driveway Final | Drainage Cover | Water Heater Final |
| Sidewalk/Flatwork/Pavers Steel | Drainage Final | Irrigation Trench / Final |
| Sidewalk/Flatwork/Paver Final | Fire Sprinkler Cover / Final | Other/Miscellaneous |

CONTRACTOR NAME: Jose Sanchez

CONTACT PHONE/EMAIL: 4A Group Inc.

INSPECTOR COMMENTS: Drainage side drainage (M) 545-8179

PASS FAIL
 DATE: 6/9/22
 TIME: 1:00
 INSPECTOR: Aaron Crowley

Re-Inspection Fee Required

- Ok to cover pipes that have been installed and marked on plan
- Still need to inspect 6" pipe on ~~the~~ southwest side of lot
- Inlets still need to be installed and inspected
- Reinforced ~~the~~ filter fabric fencing needs to be installed around lot and inspected