

# REQUEST FOR INSPECTION

CALL DATE: 11-15-22 TIME 11:55 AM PM

PROPERTY ADDRESS: 11311 Piney Point Cir PERMIT NUMBER: 19156

### INSPECTOR

Bob Baldwin  
  Jason Bienek  
  Gary Moran  
  Jose Gomez  
  City Engineer \_\_\_\_\_

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
<b>Hurricane Strapping – Exterior Wall</b>	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof-Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: McCollum Custom

CONTACT PHONE/EMAIL: None

INSPECTOR COMMENTS: 832-723-8428

**PASS**      **FAIL**

DATE: 11-15-22

TIME: 11:55

INSPECTOR: JASON

Re-Inspection Fee Required

Neal Code 6789