

## REQUEST FOR INSPECTION

CALL DATE: 12-12-22 TIME 2:00 AM/PM PM 18297  
 PROPERTY ADDRESS: 11219 Claymore PERMIT NUMBER: ~~18297~~

### INSPECTION INFORMATION

INSPECTOR:  Bob Baldwin  Jason Bienek  Cary Moran  City Engineer \_\_\_\_\_

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TCI	Plumbing Sewer Line
Poly Seal	Electrical Reconnect	Plumbing Ground
Insulation	Pool Electrical Underground	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Cover	Plumbing Gas (GTO- House)
Brick Tie	Pool Electrical Final	Plumbing Cover
Stucco Lathe	<u>Electrical Final</u>	Plumbing Final
Building Final	Temporary Drainage	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Partial	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Cover	Plumbing Pool Final
Driveway Final	Drainage Final	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Cover	Irrigation Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Final	Other/Miscellaneous

CONTRACTOR NAME: Corinthian Cont  
 CONTACT PHONE/EMAIL: \_\_\_\_\_  
 INSPECTOR COMMENTS: \_\_\_\_\_

PASS  **FAIL**

DATE: 12-12-22  
 TIME: 2:00  
 INSPECTOR: JASON

Range Outlet Dirty K. Top  
Needs GFI Protection  
Need to Add plugs kitchen Countertops  
left and right of sink, North Counter top  
missing covers by wine room, dining Rm  
MS+ Bath,  
missing Arc Fault Protection Lighting Circuit  
Need to relocate Arc to room 12)

Re-Inspection Fee Required