REQUEST FOR INSPECTION

NEQUEST FOR INSPECTION		
CALL DATE: 4-10-23 TIME 12:00 (AM) PM		
PROPERTY ADDRESS: 583 Magnolia Cin PERMIT NUMBER: 17960		
INSPECTOR		
□ Bob Baldwin □ Jason Bienek □ Sary Moran □ Jose Gomez □ City Engineer		
Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous
CONTRACTOR NAME: KAND Electric		PASS FAIL
CONTACT PHONE/EMAIL: <u>936-701-8120</u>		DATE: 4-10-23
INSPECTOR COMMENTS:		TIME: /2.00
Box. Botheam	Kitchen !	INSPECTOR: JASon
BATHROOMS- Need 6FF Project Re-Inspection Fee Required		
Fixture missing lauder Both		
Heed to Kelocoti Disc in Meckmical Close		
Heed plug & County in p. Room		
Bewood plus - look of Code		
Deed light in Decenty Closef		
Missing Plate in Combinet		
Not Fivisked		