

REQUEST FOR INSPECTION

CALL DATE: 4-12-23 TIME _____: _____ AM / PM
 PROPERTY ADDRESS: 12 Shady Grove PERMIT NUMBER: 19455

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer _____

| | | |
|-------------------------------------|--------------------------------------|--------------------------------------|
| Demolition | Generator Concrete Steel Pad | Mechanical Cover |
| Temporary Tree Protection Fencing | Generator Final - Operative | Mechanical Vent Hood |
| Pre-Construction Site | Fence Post Hole | <u>Mechanical Grill Seal</u> |
| Piers | Fence Final | Mechanical Box Seal |
| Foundation Repair | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up |
| Foundation Steel – Survey Verified | Deck Steel / Pool Steel | Mechanical Final |
| Hurricane Strapping – Exterior Wall | Deck Final / Pool Final | Mechanical Change Out |
| Wall Board Exterior | Roof Final | Mechanical Cover (Wine Room) |
| Ridge Height - Verification | Synthetic Turf | Mechanical Final (Wine Room) |
| Stair Compliance | Electrical T-Pole | Sewer Disconnect |
| Framing Only | Electrical Cover | Plumbing Water Line |
| Frame Cover | Electrical Ditch Cover | Plumbing Sewer Line |
| Poly Seal | Electrical TCI | Plumbing Ground |
| Insulation | Electrical Reconnect | Plumbing Shower Pan/Wall Board |
| Wall Board Interior | Pool Electrical Underground | Plumb Gas: House / Pool / Generator |
| Brick Tie | Pool Electrical Cover | Plumbing Cover |
| Stucco Lathe | Pool Electrical Final | Plumbing Final |
| Building Final | Electrical Final | Pool Plumbing Cover |
| Tree Final | Temporary Drainage | Pool Plumbing Vacuum Breaker, P-Trap |
| Driveway / Steel | Drainage Partial | Plumbing Pool Final |
| Driveway Final | Drainage Cover | Water Heater Final |
| Sidewalk/Flatwork/Pavers Steel | Drainage Final | Irrigation Trench / Final |
| Sidewalk/Flatwork/Paver Final | Fire Sprinkler Cover / Final | Other/Miscellaneous |

CONTRACTOR NAME: Custom Contract

CONTACT PHONE/EMAIL: 7-907-2463

INSPECTOR COMMENTS: _____

PASS FAIL

DATE: 4-12-23

TIME: 12:00

INSPECTOR: [Signature]

Re-Inspection Fee Required

Exhaust fan at Master
Both tub not sealed.
Upstairs west room box not sealed.
Upstairs east side both vent covered
with grill so can't inspect.

Must have permit posted
Encl all mechanical inspection