

## REQUEST FOR INSPECTION

CALL DATE: 4/25/23 TIME \_\_\_\_\_: \_\_\_\_\_ AM / PM

PROPERTY ADDRESS: 3 Smithdale Est PERMIT NUMBER: #1917

### INSPECTOR

Bob Baldwin 
  Jason Bienek 
  Cary Moran 
  Jose Gomez 
  City Engineer

*Cole w/ Co  
HBR Engrin*

|                                     |                                      |                                      |
|-------------------------------------|--------------------------------------|--------------------------------------|
| Demolition                          | Generator Concrete Steel Pad         | Mechanical Cover                     |
| Temporary Tree Protection Fencing   | Generator Final - Operative          | Mechanical Vent Hood                 |
| Pre-Construction Site               | Fence Post Hole                      | Mechanical Grill Seal                |
| Piers                               | Fence Final                          | Mechanical Box Seal                  |
| Foundation Repair                   | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up               |
| Foundation Steel – Survey Verified  | Deck Steel / Pool Steel              | Mechanical Final                     |
| Hurricane Strapping – Exterior Wall | Deck Final / Pool Final              | Mechanical Change Out                |
| Wall Board Exterior                 | Roof Final                           | Mechanical Cover (Wine Room)         |
| Ridge Height - Verification         | Synthetic Turf                       | Mechanical Final (Wine Room)         |
| Stair Compliance                    | Electrical T-Pole                    | Sewer Disconnect                     |
| Framing Only                        | Electrical Cover                     | Plumbing Water Line                  |
| Frame Cover                         | Electrical Ditch Cover               | Plumbing Sewer Line                  |
| Poly Seal                           | Electrical TCI                       | Plumbing Ground                      |
| Insulation                          | Electrical Reconnect                 | Plumbing Shower Pan/Wall Board       |
| Wall Board Interior                 | Pool Electrical Underground          | Plumb Gas: House / Pool / Generator  |
| Brick Tie                           | Pool Electrical Cover                | Plumbing Cover                       |
| Stucco Lathe                        | Pool Electrical Final                | Plumbing Final                       |
| Building Final                      | Electrical Final                     | Pool Plumbing Cover                  |
| Tree Final                          | Temporary Drainage                   | Pool Plumbing Vacuum Breaker, P-Trap |
| Driveway / Steel                    | Drainage Partial                     | Plumbing Pool Final                  |
| Driveway Final                      | Drainage Cover                       | Water Heater Final                   |
| Sidewalk/Flatwork/Pavers Steel      | <u>Drainage Final</u>                | Irrigation Trench / Final            |
| Sidewalk/Flatwork/Paver Final       | Fire Sprinkler Cover / Final         | Other/Miscellaneous                  |

CONTRACTOR NAME: Jerry Simmons  
 CONTACT PHONE/EMAIL: #832-938-0609  
 INSPECTOR COMMENTS: Avg Pools

PASS FAIL  
 DATE: 4/25/23  
 TIME: 11:00  
 INSPECTOR: *[Signature]*

Re-Inspection Fee Required

- Final inspection must have all sod/landscape in and silt fence removed.
- Many areas in front, side, and rear yard have not been sodded or graded.
- Appears Turf raised may be breaking fill ordinance
- Appears previously approved drainage inlets have been covered with turf. Site will not drain as proposed on drainage plan.