

REQUEST FOR INSPECTION

CALL DATE: 8/17/2023 TIME: _____: _____ (AM/PM) PM

PROPERTY ADDRESS: 3 Fernham Park PERMIT NUMBER: 20013 *W/leal #12k and*

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer

#12k and
20013

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	<u>Drainage Cover</u>	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Rigo Fernandez

CONTACT PHONE/EMAIL: (281) 541-6706 (P)

INSPECTOR COMMENTS: pool drains & deck area drains down spouts.

PASS **FAIL**

DATE: 8/18/23

TIME: 2:00

INSPECTOR: Aaron Cook

Re-Inspection Fee Required

- Inlet adjacent to southwest corner of pool appears to be cracked. Replace or repair inlet

- Recommend filling bottoms of all inlets w/ grout up to flow lines of pipes to prevent standing water