

REQUEST FOR INSPECTION

CALL DATE: 8/17/2023 TIME: : AM/PM
 PROPERTY ADDRESS: 9 Toleheke Trail PERMIT NUMBER: 24 18396

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer *cole w HDZencin*

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final <i>D</i>	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: 300 Builders / 6119 2214 593 **PASS** **FAIL**
 CONTACT PHONE/EMAIL: Clayton Lemahoff
 INSPECTOR COMMENTS: Drainage Final
 DATE: 8/18/23
 TIME: 12:30
 INSPECTOR: Aaron Coakley

- Re-Inspection Fee Required
- Appears inlet is missing along east side of lot in backyard as shown on latest approved drainage plans
 - Southeast corner of lot needs to be graded towards interior inlets
 - Need to uncover inlet in landscaping area adjacent to west side of driveway
 - Still need to install 10" sump overflow pipe