REQUEST FOR INSPECTION

CALL DATE: 3/9/23 TIME : AM/PM		
PROPERTY ADDRESS: 11103 Hodwig LN PERMIT NUMBER: # 19307		
INSPECTOR □ Bob Baldwin □ Jason Bienek □ Cary Moran □ Jose Gomez □ City Engineer □ Conquin		
Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection	Generator Final - Operative	Mechanical Vent Hood
Fencing Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Dramage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous
		PASS FAIL
CONTRACTOR NAME: 1. Snardo Kamirez		DATE: 3-2-23
INSPECTOR COMMENTS: X- Rain Inc.		TIME: 10:15
\bigcirc 1		INSPECTOR:
V32 /289 1511 Re-Inspection Fee Required		
Districted Final - POOL		
DO AKIT COVER until approved.		
-Bends in pipe not shown on show not allowable		
- Inlets must be box w/ FL as shown on plan, not		
bend-auxily pipe w/ grate.		
- RFFF not set up or maintained as shuin on plan		
- Pipe South east of pool not shown on plan		