

REQUEST FOR INSPECTION

CALL DATE: 3/16/23 TIME : AM / PM

PROPERTY ADDRESS: 11325 Greenbay Dr PERMIT NUMBER: 17016

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer

*Colleen HDPE
Enain*

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	<u>Drainage Partial</u>	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Dennis Williams

CONTACT PHONE/EMAIL: #713.465.7231

INSPECTOR COMMENTS: Dennis Williams + 50 inc

PASS FAIL

DATE: 3-16-23

TIME: 10:50

INSPECTOR: [Signature]

Re-Inspection Fee Required

OK to cover pipe along driveway

Inlet south of garage in rake area and inlet south of pool equip. ~~apparently~~ in grass appear to be covered by grass or are not visible. lines lead to inlet but unsure where inlet is.