

REQUEST FOR INSPECTION

CALL DATE: 3/2/23 TIME : AM / PM
 PROPERTY ADDRESS: 11411 Wmclaver PERMIT NUMBER: # 17879

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer Cole w/ HDR

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	<u>Drainage Partial</u> <u>Cover</u>	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Dennis Williams

CONTACT PHONE/EMAIL: # 713.465.7231

INSPECTOR COMMENTS: Dennis Williams & Co, Inc
Culvert & front entry

PASS FAIL
 DATE: 3/2/23
 TIME: 11:35
 INSPECTOR: [Signature]

Re-Inspection Fee Required

- RFFF needs to be replaced in areas along perimeter and around inlets.

- Culvert in ROW North of entry way not shown on Drainage Plan - Require Revision.

- Inlets / pipe near entry way covered w/o approval and not shown on Drainage Plan. - Require Revision

- Rip cap must be placed at location of outfall pipe.