REQUEST FOR INSPECTION			
CALL DATE: 3-1-23 TIME 11:15 (AM)PM PROPERTY ADDRESS: 11145 11:15 (DV) 1/4/59 PERMIT NUMBER: 19502			
INSPECTOR			
□ Bob Baldwin □ Jason Bienek □ Cary Moran □ Jose Gomez □ City Engineer			
Demolition	Generator Concrete Steel Pad	Mechanical Cover	
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood	
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal	
Piers	Fence Final	Mechanical Box Seal	
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up	
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final	
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out	
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)	
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)	
Stair Compliance	Electrical T-Pole	Sewer Disconnect	
Framing Only	Electrical Cover	Plumbing Water Line	
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line	
Poly Seal	Electrical TCI	Plumbing Ground	
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board	
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator	
Brick Tie	Pool Electrical Cover	Plumbing Cover	
Stucco Lathe	Pool Electrical Final	Plumbing Final	
Building Final	Electrical Final	Pool Plumbing Cover	
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap	
Driveway / Steel	Drainage Partial	Plumbing Pool Final	
Driveway Final	Drainage Cover	Water Heater Final	
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final	
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous	
CONTRACTOR NAME: Softmonship by Toh		PASS FAIL	
CONTACT PHONE/EMAIL: Molson		DATE: 3-1-23	
INSPECTOR COMMENTS: 713-805-9029		TIME: //:15	
1	INSPECTOR: TASON		
Generator not	botted to slab	Re-Inspection Fee Required	

	INSPECTOR: MSon
Generator not botted to slob	Re-Inspection Fee Required
" to Close to fence	
" must be screened from	n Street VIEW
11 missing E-stop Swr	teh
Need technician on Site for 11	rspection