

REQUEST FOR INSPECTION

CALL DATE: 7/12/23 TIME _____ : _____ AM / PM

PROPERTY ADDRESS: 201 Kirkland School Dr PERMIT NUMBER: #19289

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer Colc K

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Antonio Rojas

CONTACT PHONE/EMAIL: # 832.465.6378

INSPECTOR COMMENTS: Linbeck

30" storm line in front of gym

<input type="checkbox"/> PASS <input checked="" type="checkbox"/> FAIL
DATE: <u>7/12/23</u>
TIME: <u>11:20</u>
INSPECTOR: <u>Colc K</u>

Re-Inspection Fee Required

OK to cover 30" RCP along gym up to NW corner of gym as shown on plans