

REQUEST FOR INSPECTION

CALL DATE: 7/20/2023 TIME: _____ AM / PM
 PROPERTY ADDRESS: 205 Wernelwauter PERMIT NUMBER: # 18412

INSPECTOR

Bob Baldwin
 Jason Bienek
 Cary Moran
 Jose Gomez
 City Engineer Cole W/ HDR
Grain

| | | |
|-------------------------------------|--|--------------------------------------|
| Demolition | Generator Concrete Steel Pad | Mechanical Cover |
| Temporary Tree Protection Fencing | Generator Final - Operative | Mechanical Vent Hood |
| Pre-Construction Site | Fence Post Hole | Mechanical Grill Seal |
| Piers | Fence Final | Mechanical Box Seal |
| Foundation Repair | Pool Stake Out & Pool Doc Box Set Up | Mechanical Air Make Up |
| Foundation Steel – Survey Verified | Deck Steel / Pool Steel | Mechanical Final |
| Hurricane Strapping – Exterior Wall | Deck Final / Pool Final | Mechanical Change Out |
| Wall Board Exterior | Roof Final | Mechanical Cover (Wine Room) |
| Ridge Height - Verification | Synthetic Turf | Mechanical Final (Wine Room) |
| Stair Compliance | Electrical T-Pole | Sewer Disconnect |
| Framing Only | Electrical Cover | Plumbing Water Line |
| Frame Cover | Electrical Ditch Cover | Plumbing Sewer Line |
| Poly Seal | Electrical TCI | Plumbing Ground |
| Insulation | Electrical Reconnect | Plumbing Shower Pan/Wall Board |
| Wall Board Interior | Pool Electrical Underground | Plumb Gas: House / Pool / Generator |
| Brick Tie | Pool Electrical Cover | Plumbing Cover |
| Stucco Lathe | Pool Electrical Final | Plumbing Final |
| Building Final | Electrical Final | Pool Plumbing Cover |
| Tree Final | Temporary Drainage | Pool Plumbing Vacuum Breaker, P-Trap |
| Driveway / Steel | Drainage Partial | Plumbing Pool Final |
| Driveway Final | <u>Drainage Cover</u> <small>re-inspection</small> | Water Heater Final |
| Sidewalk/Flatwork/Pavers Steel | Drainage Final | Irrigation Trench / Final |
| Sidewalk/Flatwork/Paver Final | Fire Sprinkler Cover / Final | Other/Miscellaneous |

CONTRACTOR NAME: Jim Bob Taylor - W.D.L Doyle Co
 CONTACT PHONE/EMAIL: or Dennis Ad Wilcains - christina (7) 405-7231101
 INSPECTOR COMMENTS:

PASS FAIL
 DATE: 7-20-23
 TIME: 12:20
 INSPECTOR: [Signature]

Trash around site needs to be picked up. Re-Inspection Fee Required

Many inlets have "lip" that does not allow water to flow as shown on the temporary drainage plan grade to inlets.

Deteriorated filter fabric needs to be reset.