

# REQUEST FOR INSPECTION

CALL DATE: 7-28-23 TIME: \_\_\_\_\_: \_\_\_\_\_ AM/PM  
 PROPERTY ADDRESS: 9 Tokeneke Trail PERMIT NUMBER: \_\_\_\_\_

## INSPECTOR

Bob Baldwin  Jason Bienek  Cary Moran  Jose Gomez  City Engineer \_\_\_\_\_

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">Plumbing Final</span>
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: iPlumb  
 CONTACT PHONE/EMAIL: 7-473-1300 Isaac  
 INSPECTOR COMMENTS: \_\_\_\_\_

PASS FAIL

DATE: 7-27-23  
 TIME: \_\_\_\_\_  
 INSPECTOR: BBB 333

Water Heater T&P drain lines must terminate within 6" of ground. Missing screen outside for floor drain. Range not lighting. No hot water. Powder room sink not working. Missing escutcheon plates. Only inspected 1st floor. Please punch out home to make sure water heaters are on.

Re-Inspection Fee Required