

REQUEST FOR INSPECTION

CALL DATE: 9/14/23 TIME _____ : _____ AM / PM
 PROPERTY ADDRESS: 11311 Pines Point Cir PERMIT NUMBER: # 19051

INSPECTOR

Bob Baldwin Jason Bienek Cary Moran Jose Gomez City Engineer Cole K

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel - Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping - Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	Plumbing Final
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	<u>Drainage Cover</u>	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Joan Van Heerden

CONTACT PHONE/EMAIL: # 713 869 7946

INSPECTOR COMMENTS: Paragon Pools

PASS FAIL

DATE: 9-14-23

TIME: 12:00

INSPECTOR: Cole K.

Re-Inspection Fee Required

- RFFF not placed around perimeter and on all inlets as shown on plan.
- Inlet on ~~SW~~ SW corner of house not shown on plan. 6" pipes along N of pool not shown on plan.
- Previously placed inlets are higher than surrounding ground, ground settled. Site not draining as proposed by Temporary Drainage plan.
- DO NOT cover pool pipes, OK to cover downspout pipes