

# REQUEST FOR INSPECTION

CALL DATE: 3-1-24 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 PROPERTY ADDRESS: 11111 Meadowick Dr PERMIT NUMBER: 19185

## INSPECTOR

Bob Baldwin  Jason Bienek  Cary Moran  Jose Gomez  City Engineer \_\_\_\_\_

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final / Pool Final	Mechanical Change Out
Wall Board Exterior	Roof Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Synthetic Turf	Mechanical Final (Wine Room)
Stair Compliance	Electrical T-Pole	Sewer Disconnect
Framing Only	Electrical Cover	Plumbing Water Line
Frame Cover	Electrical Ditch Cover	Plumbing Sewer Line
Poly Seal	Electrical TCI	Plumbing Ground
Insulation	Electrical Reconnect	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Underground	Plumb Gas: House / Pool / Generator
Brick Tie	Pool Electrical Cover	Plumbing Cover
Stucco Lathe	Pool Electrical Final	<u>Plumbing Final</u>
Building Final	Electrical Final	Pool Plumbing Cover
Tree Final	Temporary Drainage	Pool Plumbing Vacuum Breaker, P-Trap
Driveway / Steel	Drainage Partial	Plumbing Pool Final
Driveway Final	Drainage Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Drainage Final	Irrigation Trench / Final
Sidewalk/Flatwork/Paver Final	Fire Sprinkler Cover / Final	Other/Miscellaneous

CONTRACTOR NAME: Stratton Plumbing

CONTACT PHONE/EMAIL: Don

INSPECTOR COMMENTS: Fireplace valve

trim missing. Check all  
several out door cleanout  
in wall & ground need to trim & paint.  
& water drains must terminate with 12  
6" of ground & be painted. Kitchen  
sink not working. Floor drain outside  
is missing screen. Need Permit on site  
Inspection Incomplete

PASS FAIL

DATE: 3-1-24

TIME: 1:15

INSPECTOR: Kh B 3330

Re-Inspection Fee Required