

# REQUEST FOR INSPECTION

CALL DATE: 6-3-21 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM *plumb*  
 PROPERTY ADDRESS: 11101 Beinhorn  
 PERMIT NUMBER: 17887

### INSPECTION INFORMATION

DATE PERFORMED: 6-3-21 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 INSPECTOR: 1) Bob Baldwin 4) Jason Bienek \_\_\_\_\_  
 2) Cary Moran \_\_\_\_\_ 5) Other \_\_\_\_\_  
 3) City Engineer \_\_\_\_\_

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	Plumbing Ground	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	Plumbing Gas (GTO- House)	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	<u>Plumbing Final</u>	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: John Moore  
 CONTACT PHONE/EMAIL: 281-517 6696  
 INSPECTOR COMMENTS: \_\_\_\_\_

<b>PASS</b>	<b>FAIL</b>
DATE: <u>6-3-21</u>	
TIME: <u>6-3-21</u>	
INSPECTOR: <u>Bob B 3330</u>	

Re-Inspection Fee Required

# REQUEST FOR INSPECTION

CALL DATE: 6-1-21 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM plumb  
 PROPERTY ADDRESS: 1101 Reinhorn  
 PERMIT NUMBER: 17887

### INSPECTION INFORMATION

DATE PERFORMED: 6-1-21 TIME \_\_\_\_\_ : \_\_\_\_\_ AM / PM  
 INSPECTOR: 1) Bob Baldwin 4) Jason Bienek \_\_\_\_\_  
 2) Cary Moran \_\_\_\_\_ 5) Other \_\_\_\_\_  
 3) City Engineer \_\_\_\_\_

Demolition (Main House)	Sidewalk/Flatwork/Pavers Steel	Electrical Ditch Cover
Demolition (Pool Only)	Sidewalk/Flatwork/Paver Final	Electrical TCI
Temporary Tree Protection Fencing	Generator Concrete Steel Pad	Electrical Final
Pre-Construction Site	Generator Final - Operative	Mechanical Vent Hood
Piers	Partial Trench Inspection	Mechanical Grill Seal
Foundation Repair	Trench Inspection	Mechanical Box Seal
Foundation Steel – Survey Verified	Irrigation Final	Mechanical Air Make Up
Hurricane Strapping – Exterior Wall	Fence Partial Post Hole	Mechanical Final
Wall Board Exterior	Fence Post Hole	Mechanical Cover (Wine Room)
Ridge Height	Fence Final	Mechanical Final (Wine Room)
Stair Compliance	Temporary Drainage	Fire Sprinkler Cover
Framing Only	Drainage Partial	Fire Sprinkler Final
Frame Cover	Drainage Cover	Pool Stake Out & Pool Doc Box Set Up
Poly Seal	Drainage Culvert	Deck Steel
Insulation	Drainage Final	Deck Final
Wall Board Interior	Plumbing Water Line	Pool Final
Brick Tie	Plumbing Sewer Line	Pool Electrical Underground
Stucco Lathe	Plumbing Ground	Pool Electrical Cover
Building Final	Plumbing Shower Pan/Wall Board	Pool Electrical Final
Tree Final	Plumbing Gas (GTO- House)	Pool Plumbing Cover
Driveway / Partial	Plumbing Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	<u>Plumbing Final</u>	Plumbing Pool Final
Driveway Final	Electrical T-Pole	Water Heater Final

CONTRACTOR NAME: John Moore  
 CONTACT PHONE/EMAIL: 832-256-1002  
 INSPECTOR COMMENTS: Renee Sanders

<b>PASS</b> <b>FAIL</b>
DATE: <u>6-1-21</u>
TIME: <u>11:55</u>
INSPECTOR: <u>Bob 3330</u>

Re-Inspection Fee Required

T & P drain pipe must be terminate within 6 inches of ground.  
pan drain must be between 6-24 inches above the ground. Put them all at 6" above grade.