

REQUEST FOR INSPECTION

CALL DATE: 7-19-21 TIME 11:45 : AM / PM
 PROPERTY ADDRESS: 11310 Travis Gap PERMIT NUMBER: 17711

INSPECTION INFORMATION

INSPECTOR: Bob Baldwin Jason Bienek Cary Moran City Engineer _____

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final	Mechanical Change Out
Wall Board Exterior	Pool Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TCI	Plumbing Sewer Line
Poly Seal	Pool Electrical Underground	Plumbing Ground
Insulation	Pool Electrical Cover	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Final	Plumbing Gas (GTO- House)
Brick Tie	Electrical Final	Plumbing Cover
Stucco Lathe	Temporary Drainage	Plumbing Final
Building Final	Drainage Partial	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Drainage Final	Plumbing Pool Final
Driveway Final	Fire Sprinkler Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Final	Irrigation Final
Sidewalk/Flatwork/Paver Final	Other/Miscellaneous	PASS FAIL

CONTRACTOR NAME: Spartan Interiors DATE: 7-19-21
 CONTACT PHONE/EMAIL: 7-409-5249 TIME: 11:45
 INSPECTOR COMMENTS: _____ INSPECTOR: BBB

Do not cover until Hood makeup air is connected & working & the makeup air has been scheduled & passed.

Re-Inspection Fee Required