

REQUEST FOR INSPECTION

CALL DATE: 7-22-21 TIME : AM / PM
 PROPERTY ADDRESS: 1 S. Checka Tr PERMIT NUMBER: 18005

INSPECTION INFORMATION

INSPECTOR: Bob Baldwin Jason Bienek Cary Moran City Engineer _____

Demolition	Generator Concrete Steel Pad	Mechanical Cover
Temporary Tree Protection Fencing	Generator Final - Operative	Mechanical Vent Hood
Pre-Construction Site	Fence Post Hole	Mechanical Grill Seal
Piers	Fence Final	Mechanical Box Seal
Foundation Repair	Pool Stake Out & Pool Doc Box Set Up	Mechanical Air Make Up
Foundation Steel – Survey Verified	Deck Steel / Pool Steel	Mechanical Final
Hurricane Strapping – Exterior Wall	Deck Final	Mechanical Change Out
Wall Board Exterior	Pool Final	Mechanical Cover (Wine Room)
Ridge Height - Verification	Electrical T-Pole	Mechanical Final (Wine Room)
Stair Compliance	Electrical Cover	Sewer Disconnect
Framing Only	Electrical Ditch Cover	Plumbing Water Line
Frame Cover	Electrical TCI	Plumbing Sewer Line
Poly Seal	Pool Electrical Underground	Plumbing Ground
Insulation	Pool Electrical Cover	Plumbing Shower Pan/Wall Board
Wall Board Interior	Pool Electrical Final	Plumbing Gas (GTO-House)
Brick Tie	Electrical Final	Plumbing Cover <i>Generator</i>
Stucco Lathe	Temporary Drainage	Plumbing Final
Building Final	Drainage Partial	Pool Plumbing Cover
Irrigation Trench / Tree Final	Drainage Cover	Pool Plumbing Vacuum Breaker, P-Trap, Gas Final
Driveway / Steel	Drainage Final	Plumbing Pool Final
Driveway Final	Fire Sprinkler Cover	Water Heater Final
Sidewalk/Flatwork/Pavers Steel	Fire Sprinkler Final	Irrigation Final
Sidewalk/Flatwork/Paver Final	Other/Miscellaneous	<input type="checkbox"/> PASS <input checked="" type="checkbox"/> FAIL

CONTRACTOR NAME: Sagle Plumbing
 CONTACT PHONE/EMAIL: 281 802 7208
 INSPECTOR COMMENTS: _____

DATE: 7-23-21
 TIME: 10:30
 INSPECTOR: BBB 3330

No Access. Gas line must be out test with a low pressure Gauge

Re-Inspection Fee Required